



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	10-21-03	Interpretation #	03-035
Topic	Window Security Grill Release Mechanisms		
Code Section(s)	§305.2.4, California Building Code (2002 ed)		
Requested by	John Merrick MPAG 1818 W. Chapman Ave, Suite J Orange, CA 92868		

***Is §305.2.4 limited to relocatable classrooms? If so, how is this requirement applied to two-story relocatable classroom buildings? If this code section is applicable to permanent buildings, how does the height above grade affect the need for the window release mechanism?***

No. §305.2.4 is applicable to both relocatable and permanent structures used for Group E occupancies. The height above grade does not affect the requirement for the window release mechanism.